

PORTABLE APPLIANCE TEST RECORD

Appliance		Serial Number	
Customer			
Supply Voltage	230 volts AC 50Hz	Fuse Rating	5 Amp

CTS (Europe) Ltd certifies the above instrument meets the correct specifications and has been calibrated using instruments of known accuracies, which are traceable to UKAS accreditation.

Visual Checks	Power Lead	✓
	Cable retention	✓
	Plug Intact	✓
	Fusing Correct	✓
	Casing Correct	✓

Pat Test Results	Earth Bond Test:	Ω
	Insulation Test (Meg Ohms)	MΩ



PASS



FAIL

Test Equipment:	Serial no.:	Calibration Company:	Calibration Date:	Calibration Expiry:
Seaward PrimeTest 100	40M-0550	Compli Group Ltd.	15 June 2026	15 June 2027

Date of Test:	
Engineer Name:	
Approved Signatory:	
Signature:	ATwiss-Savage

Uncertainties

Portable Appliance Tester: Seaward PrimeTest 100 (Measurement Uncertainty: 0.1 Mohm 2v) Reported expanded uncertainties are based on a standard uncertainty multiplied by a coverage factor K=2, providing a level of confidence of approximately 95%. The Uncertainty evaluation has been carried out in accordance to UKAS Requirements.